



1. Accessibility Assessment of the Campus Chapel (Kampuskappeli)

Subject: Accessibility assessment of the Campus Chapel (Kampuskappeli) (address: Rehtorinpellonkatu 4 A, Student House C (Ylioppilastalo C), 20500 Turku) 17 October 2019. This memo was submitted to the Student Union of the University of Turku on 16 December 2019.

Present: **Taru Luukkala, Kynnys ry Turku**
 Olli Norberg, Regional Secretary, Kynnys ry Turku
 Paula Pietilä, Accessibility Planning Officer, University of Turku
 Teppo Lindberg, Caretaker of Premises, Student Union of the University of Turku
 Ville Ritola, Specialist in Social Affairs, Student Union of the University of Turku

Entrance

There is a gentle and relatively long ramp at the entrance of the Campus Chapel. There is no automation on the entrance door, and there is a small threshold under the door.

Interior and toilet

Movement in the premises is unobstructed. The colour contrast between the ceiling and the floor is good.

In the chapel toilet, the free space required for turning a wheelchair is slightly inadequate. There is 80cm of free space to the right of the toilet seat. The seat is of normal height. A good toilet seat height in an accessible toilet is 46–48cm. The toilet door lacks a pull handle, and there is no device to enable calling for help.